

Conditions of Approval

Prior to Release Requirements

If this Development Permit is approved, the following requirements shall be met prior to the release of the permit. All requirements shall be resolved to the satisfaction of the Approving Authority:

Planning:

1. Submit a complete digital set of the amended plans in PDF format and a separate PDF that provides a point-by-point explanation as to how each of the Prior to Release conditions were addressed and/or resolved. The submitted plans must comprehensively address the Prior to Release conditions as specified in this document. Ensure that all plans affected by the revisions are amended accordingly. To arrange the digital submission, please contact your File Manager directly.

Development Engineering:

2. Submit three (3) sets of the Development Site Servicing Plan details to Development Servicing, Inspections and Permits, for review and acceptance from Water Resources, as required by Section 5 (2) of the *Utility Site Servicing Bylaw 33M2005*. Contact developmentservicing2@calgary.ca for additional details.

For further information, refer to the following:

Design Guidelines for Development Site Servicing Plans

http://www.calgary.ca/PDA/pd/Documents/urban_development/publications/DSSP2015.pdf

Development Site Servicing Plans CARL (requirement list)

<http://www.calgary.ca/PDA/pd/Documents/development/development-site-servicing-plan.pdf>

3. Follow the submission requirements outlined in Section 3.0 of The City of Calgary Guidelines for Erosion and Sediment Control (Erosion and Sediment Control Reports and Drawings: Technical Requirements) and either submit the required (2) copies of an Erosion and Sediment Control (ESC) Report and Drawings or the required (2) copies of a Written Notice to Development Engineering, for review and acceptance by Stormwater Pollution Prevention (SPP), Water Resources. The City of Calgary Guidelines for Erosion and Sediment Control can be accessed at: www.calgary.ca/esc (under Approvals).


Documents submitted shall conform to the requirements detailed in the current edition of The City of Calgary *Guidelines for Erosion and Sediment Control* and shall be prepared, signed and stamped by a qualified consultant specializing in erosion and sediment control, and holding current professional accreditation as a Professional Engineer (P. Eng.), Professional Licensee (P.L. Eng), Professional Agrologist (P. Ag.) or Certified Professional in Erosion and Sediment Control (CPESC). For each stage of work where soil is disturbed or exposed, documents must clearly specify the location, installation, inspection and maintenance details and requirements for all temporary and permanent controls and practices.

Conditions of Approval

If you have any questions, contact 3-1-1. A Service Request (SR) will be created for the Erosion Control Team in Water Resources.

Transportation:

- Amend the plans to indicate **all** driveway edges to be single lines (not double lines). Single lines indicate driveway flares while double lines indicate curbs, which are not permitted.



- Remit a performance security deposit (certified cheque, bank draft, letter of credit) for the proposed infrastructure listed below within the public right-of-way to address the requirements of the Business Unit. The amount of the deposit is calculated by Roads and is based on 100% of the estimated cost of construction. The developer is responsible to arrange for the construction of the infrastructure with their own forces and to enter into an Indemnification Agreement with Roads at the time of construction (the security deposit will be used to secure the work).

Roads

- Construction of two new driveway crossings on 37 Street NW,
 - Construction of rolled curb along the fire truck apron,
 - Construction of new sidewalks along 37 Street NW directly adjacent to the site,
 - Rehabilitation of existing driveway crossings, sidewalks, curb and gutter, etc., along the 37 Street NW frontage, should it be deemed necessary through a site inspection by Roads personnel.
- Remit payment (certified cheque, bank draft) for the proposed infrastructure listed below within the public right-of-way to address the requirements of the Business Units. The amount is calculated by the respective Business Unit and is based on 100% of the estimated cost of construction.

The developer is responsible to coordinate the timing of the construction by City forces. The payment is non-refundable.

Roads

- Street lighting along 37 Street NW directly adjacent to the site.

Conditions of Approval

7. Remit payment (certified cheque, bank draft) for provision of conflict (paint) marking and signage along 37 Street NW to provide enhanced definition for the existing bike lanes based on the accesses being constructed to service this development.

Contact Traffic Control and Signage at (403) 268-4426 to confirm payment amount.

Parks:

8. Submit confirmation from Urban Forestry of the approved Tree Protection Plan/removal, as per the Tree Protection Bylaw. Contact Urban Forestry at 311 or tree.protection@calgary.ca to arrange for Tree Protection Plan approval.

Permanent Conditions

If this Development Permit is approved, the following permanent conditions shall apply:

Planning:

9. The development shall be completed in its entirety, in accordance with the approved plans and conditions.
10. No changes to the approved plans shall take place unless authorized by the Development Authority.
11. A Development Completion Permit shall be issued for the development **before the use is commenced or the development occupied**. A Development Completion Permit is independent from the requirements of Building Permit occupancy. Call Development Inspection Services at 403-268-5311 to request a site inspection for the Development Completion Permit.
12. The Child Care Service is restricted to a maximum of 60 children at any one time.
13. All roof top mechanical equipment shall be screened as shown on the approved plans.
14. Upon completion of the main floor (storey) subfloor of each building, proof of the geodetic elevation of the constructed main floor (storey) subfloor must be submitted to and approved by the Development Authority prior to any further construction proceeding. Email confirmation to geodetic.review@calgary.ca.
15. Retaining wall(s) that are 1.2m or greater in height shall be located and constructed as shown on the approved plans released with this permit.
16. All areas of soft landscaping shall be irrigated as shown on the approved plans.
17. Parking and landscaping areas shall be separated by a 150mm (6 inch) continuous, poured in place, concrete curb or equivalent material to the satisfaction of the Development Authority, where the height of the curb is measured from the finished hard surface.

Conditions of Approval

18. Any noise or music shall be contained on the site in accordance with the Community Standards Bylaw.
19. All electrical servicing for freestanding light standards shall be provided from underground.
20. A lighting system to meet a minimum of 22 LUX with a uniformity ratio of 4:1 on pavement shall be provided.
21. Each parking stall, where located next to a sidewalk, shall have a properly anchored concrete wheel stop or equivalent material to the satisfaction of the Development Authority (100mm in height and 600mm from the front of the parking stall).
22. The waste and recycling enclosure(s) shall be kept in a good state of repair at all times.

Development Engineering:

23. Single retaining walls 1.2m in height or greater or terraced retaining walls 1.2m in height or greater with a horizontal separation between walls of less than 3.6m (3x height) require the approval of a Building Permit prior to construction.

For retaining wall(s) that meet these criteria, the developer may either:

- a. Include the retaining walls with the Building Permit for the building, or
- b. Apply for a separate Building Permit for the retaining walls.

It should be noted that the Building Permit for the building on site will not be released until the separate Building Permit for site retaining walls is approved.

24. If during construction of the development, the developer, the owner of the titled parcel, or any of their agents or contractors becomes aware of any contamination,
 - a. the person discovering such contamination shall immediately report the contamination to the appropriate regulatory agency including, but not limited to, Alberta Environment, Alberta Health Services and The City of Calgary (311).
 - b. on City of Calgary lands or utility corridors, The City of Calgary, Environmental and Safety Management division shall be immediately notified (311).
25. The developer / project manager, and their site designates, shall ensure a timely and complete implementation, inspection and maintenance of all practices specified in erosion and sediment control report and/or drawing(s) which comply with Section 3.0 of The City of Calgary Guidelines for Erosion and Sediment Control. Any amendments to the ESC documents must comply with the requirements outlined in Section 3.0 of The City of Calgary Guidelines for Erosion and Sediment Control.

For other projects where an erosion and sediment control report and/or drawings have not been required at the Prior to Release stage, the developer, or their designates, shall, as a minimum, develop an erosion and sediment control drawing and implement good housekeeping practices to protect onsite and offsite storm drains, and to prevent or mitigate the offsite transport of sediment by the forces of water, wind and construction traffic (mud-tracking) in accordance with the current edition of The City of Calgary Guidelines for Erosion and Sediment Control. Some examples of good housekeeping

Conditions of Approval

include stabilization of stockpiles, stabilized and designated construction entrances and exits, lot logs and perimeter controls, suitable storm inlet protection and dust control.

The City of Calgary Guidelines for Erosion and Sediment Control can be accessed at: www.calgary.ca/ud (under publications).

For **all soil disturbing projects**, the developer, or their representative, shall designate a person to inspect all erosion and sediment control practices a minimum of every seven (7) days and during, or within 24 hours of, the onset of significant precipitation (> 12 mm of rain in 24 hours, or rain on wet or thawing soils) or snowmelt events. Note that some practices may require daily or more frequent inspection. Erosion and sediment control practices shall be adjusted to meet changing site and winter conditions.

26. Contact the Erosion Control Inspector, Water Resources, with at least two business day's notice, to set up a pre-construction meeting prior to commencement of stripping and grading. Locations north of 17 Avenue S should contact 403-268-5271. Sites south of 17 Avenue S should contact 403-268-1847.
27. Stormwater runoff must be contained and managed in accordance with the "Stormwater Management & Design Manual" all to the satisfaction of the Director of Water Resources.
28. The grades indicated on the approved Development Site Servicing Plan(s) must match the grades on the approved Development Permit plans. Upon a request from the Development Authority, the developer or owner of the titled parcel must confirm under seal from a Consulting Engineer or Alberta Land Surveyor, that the development was constructed in accordance with the grades submitted on the Development Permit and Development Site Servicing Plan.

Transportation:

29. The developer shall be responsible for the cost of public work and any damage during construction in City road right-of-ways, as required by the Manager, Transportation Planning. All work performed on public property shall be done in accordance with City standards.
30. Indemnification Agreements are required for any work to be undertaken adjacent to or within City rights-of-way, bylawed setbacks and corner cut areas for the purposes of crane operation, shoring, tie-backs, piles, surface improvements, lay-bys, utility work, +15 bridges, culverts, etc. All temporary shoring, etc., installed in the City rights-of-way, bylawed setbacks and corner cut areas must be removed to the satisfaction of the Manager of Transportation Planning, at the applicant's expense, upon completion of the foundation. Prior to permission to construct, contact the Indemnification Agreement Coordinator, Roads at 403-268-3505.
31. The approved driveway(s) required for this development must be constructed to the ramp grades as shown on the approved Development Permit plans. Negative sloping of the driveway within the City boulevard is not acceptable. If actual grades do not match the approved grades, the developer/owner shall be responsible for all costs to remove and reconstruct the entire driveway ramp in accordance with approved grades.

Conditions of Approval

32. If Fire/Emergency Services or any other party requests signalization of the intersection of 32 Avenue and 37 Street NW in advance of the time it's warranted at the discretion of the City Traffic Engineer (Calgary Roads), then the signalization is to be funded in full by the requesting party.

Parks:

33. Any damage to public parks, boulevards or trees resulting from development activity, construction staging or materials storage, or construction access will require restoration at the developer's expense. The disturbed area shall be maintained until planting is established and approved by the Parks Development Inspector. Contact 311 for an inspection.
34. A minimum 1.2 m high fence shall remain on the property line along all shared boundaries with adjacent municipal reserve.
35. Public trees located on the boulevard and open space of the development site shall be retained and protected unless otherwise authorized by Urban Forestry. Prior to construction, install a temporary fence around the extent of the branches ("drip line") and ensure no construction materials are stored inside this fence.
36. Tree protection information given as per the approved development permit does not constitute Tree Protection Plan approval. Tree Protection Plan approval must be obtained separately through Urban Forestry. Visit www.calgary.ca or call 311 for more information.
37. The submitted plans indicate that the removal of existing public trees along property frontage is necessary. As per the City of Calgary Tree Protection By-law, a letter of authorization to remove public trees is required from Parks Urban Forestry. The applicant is to contact Urban Forestry at 311 or tree.protection@calgary.ca to make arrangements for the letter and compensation.