



Improving Calgary's Accessibility
An Accessibility Review of the
Municipal Complex



Hand Sanitizer Stations	Category: Quick Win
ADS 2016 Compliance: <ul style="list-style-type: none"> Does not meet ADS. Hand sanitizer station projects 125mm into space. Does not encroach onto the barrier-free path of travel. 	Cost Estimate for ADS 2016 Non-Compliant Items: \$ _____
ABC 2014, Section 3.8 Compliance: <ul style="list-style-type: none"> Meets ABC Section 3.8. Does not encroach onto the barrier-free path of travel. 	Cost Estimate for ABC 2014 Non-Compliant Items: \$ _____
Recommendations: <ul style="list-style-type: none"> Move existing trash / recycling bins underneath hand sanitizer stations in order to be cane detectable. 	Cost Estimate for Recommendations: \$ _____

Page | 1

Improving Calgary's Accessibility
An Accessibility Review of the
Municipal Complex



Category: Intermediate

ADS 2016 Compliance: <ul style="list-style-type: none"> Does not meet ADS. No safe or accessible drop-off zone for this site. In order for persons using wheelchairs to be dropped off at the front of the building, they must disembark into the roadway. Does not meet required width. Not clearly marked for use by people with disabilities. 	Cost Estimate for ADS 2016 Non-Compliant Items: \$ _____
ABC 2014, Section 3.8 Compliance: <ul style="list-style-type: none"> Meets ABC Section 3.8. No requirement for accessible drop-off zone, as accessible stalls provided within parkade. 	Cost Estimate for ABC 2014 Non-Compliant Items: \$ _____
Recommendations: <ul style="list-style-type: none"> Add accessible drop-off zone to main entrance of the Municipal Building at end of existing drop-off zone, closest to +15 elevator entrance in order to utilize existing curb ramp. Width of stall to be widened into existing sidewalk. Add painted stall markings and signage. 	Cost Estimate for Recommendations: \$ _____

Page | 2

Improving Calgary's Accessibility
An Accessibility Review of the
Municipal Complex



Category: Complex

ADS 2016 Compliance: <ul style="list-style-type: none"> Does not meet ADS. Existing electrical outlets are below the required mounting height. 	Cost Estimate for ADS 2016 Non-Compliant Items: \$ _____
ABC 2014, Section 3.8 Compliance: <ul style="list-style-type: none"> Meets ABC Section 3.8. 	Cost Estimate for ABC 2014 Non-Compliant Items: \$ _____
Recommendations: <ul style="list-style-type: none"> Add outlets at accessible height in lounge areas or where it is reasonably expected that the public will need to charge personal items. Do not add accessible outlets where the existing power requirements are for janitorial purposes. 	Cost Estimate for Recommendations: \$ _____

Page | 3