



Maximum Day Water Demand Comparison

Municipality	Average Day Demand (L/cap/day)	Max Day Demand (L/cap/day)	Peaking Factor
Calgary	350	585	1.7
City of Vancouver	320	512	1.6
Regina	390	702	1.8
Saskatoon	290	580	2.0
Edmonton	220	330	1.5

CITY OF CALGARY
RECEIVED
IN COUNCIL CHAMBER
JAN 16 2024
ITEM: 7.3.1 - IP2023 - 1264
Distrib-Supplemental Slide
CITY CLERK'S DEPARTMENT